



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2024/ 766

Dated: 06/08/2024

FIRE SAFETY CERTIFICATE

Certified that the **Salwan Public School Located at Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi-110096**, building comprised of **ground plus four upper floors** owned/occupied by **Salwan Public School**, was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/628 dated 23/03/2021. The School building was re-inspected by the officer concerned of this department on 23/07/2024 in presence of Mr. Maj. Gen. Ajay Khandpur VSM (Retd.) (Director) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class **"Educational Building" (Group-B)** ground + 4 upper floors only with effect from 06/08/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below

Issued on 06/08/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, D-Block, Anand Vihar, Delhi-110091.
2. The Principal, Salwan Public School Located at Kondli Gharouli Complex, Mayur Vihar, Phase-III, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any..


Principal,
Salwan Public School
Mayur Vihar Phase-III,
Delhi-110096

The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of the Delhi Fire Service Rule 2010. The form is available on www.dfs.delhi.gov.in
Principal,
Salwan Public School
Kondli Gharouli Complex
Mayur Vihar Phase-III,
Delhi-110096